

NOTE: Concrete to be CLASS 'A' ( 6 bag min.)

REVISIONS			
NO.	DATE	BY	REMARKS
1	Feb. 1984	RTH	Change width from 30" to 33"
2	5-30-85	L.R.H.	REMOVED DIV. OF PUBLIC WORKS (T. BLK.)
3	7-8-87	D. H. G.	REPLACE 3000 PSI WITH CLASS 'A'
4	1-29-88	D.H. G.	REPLACED DEPARTMENT (T.BLK.)
			4
	,		
			A CALL

## CONVERSIONS ENGLISH METRIC

## NOTES:

- I. Pre=cut exp. joint material shall be used in all exp. joints.
- 2. Dummy joints shall be installed at 10 ft. intervals, maximum.
- 3. Exp. joints shall be installed at 40 ft., maximum.
- 4. Exp. joints shall be located at ends of radius.
- 5. Exp. joints shall be located a minimum of 5 ft. from inlet structure.

CITY OF MEMPHIS
DIVISION OF ENGINEERING

DESIGN STANDARD FOR

VALLEY GUTTER

Jui E. James D. Sur D.

5-7-81

DATE

DWG. NO. 3